



01 July 2004

Question:

Std: NZS4541:2003

Is it the intent of clause 605.1.10 that additional stop valves (other than the one at water source and the main stop valve) may be fitted to the fire main on an unlooped Class C supply on a private site?

Interpretation:

Issued by the Fixed Fire Protection Group

Yes, if approved by the SSC.

**Reviewed in 2008 and deemed not applicable to NZS 4541:2007
(applies to 2003 edition)**

FI 024